

**PUBLIC COMPANY ORLEN LIETUVA
HEAD OF POWER PLANT**

Engineering Services Procurement Manager
Asta Valienė

Deputy Director of Maintenance
Vaidas Saldukas

**MEMORANDUM
REGARDING REQUIREMENTS APPLICABLE TO CONTRACTING ORGANIZATIONS
FOR WORKS IN POWER PLANT**

29 November 2013 No T18(1.52-4)-1265
Juodeikiai Vill., Mažeikiai Distr. Municipality

1. Requirements for presentation of certificates

In Power Plant, prior to proceeding with works in heating and power facilities which require to hold certificate issued by State Energy Inspectorate entitling to carry out such type of works, legal entities shall be under obligation to present copies of respective effective documents (certificates).

2. Occupational safety requirements

Works in heating (mechanical) facilities of Power Plant shall be carried out under INSTRUCTIONS and ASSIGNMENTS according to requirements established in the Rules for Safe Operation of Heating Facilities as approved with Order No 316 of 21 September 1999 by the Minister of Economy of the Republic of Lithuania.

Works in power facilities of Power Plant shall be carried out under INSTRUCTIONS and ASSIGNMENTS according to requirements established in the Rules for Safe Operation of Power Facilities as approved with Order No 1-100 of 30 March 2010 by the Minister of Energy of the Republic of Lithuania.

Prior to proceeding with works in heating and power facilities of Power Plant, legal entities shall be under obligation to provide the Head of Power Plant with list of employees (including subcontractors) indicating their qualification according to sample forms provided in Annex 1 and Annex 2 hereto. Duly filled out form(s) must be printed out on the letterhead of legal entity and signed by the executive head of this legal entity or other authorized employee and registered. Filled out form(s) must be presented or sent to the Administrator of Power Plant by fax: +370-443-93555 or scanned and e-mailed to: dalia.rackauskyte@orlenlietuva.lt.

Presented lists of employees shall remain effective for no longer than 12 months.

ATTACHED: 2 sheets.

Head of Power Plant

Remigijus Kalkauskas

(sample list when works will be performed in heating (mechanical) facilities)*(to be printed out on the letterhead of legal entity)*

Public Company ORLEN Lietuva
Head of Power Plant
Remigijus Kalkauskas

Fax: +370-443-93555

REGARDING ASSIGNMENT OF RESPONSIBLE PERSONS

Execution of works in heating (mechanical) facilities of Power Plant is hereby assigned to:

No.	Name, surname	Position	Energy Employee Certificate No ¹
	Work Managers		
1.	Name Surname, tel.: 6-666-66666	Foreman	286
2.	Name Surname, tel.: 6-666-66666	Engineer	21
	Work Executors		
1.	Name Surname, tel.: 6-666-66666	Metalworker	78
2.	Name Surname, tel.: 6-666-66666	Metalworker	508
	Members of the crew		
1.	Name Surname	Metalworker	670
2.	Name Surname	Metalworker	58
3.	Name Surname	Fitter	178
4.	Name Surname	Welder	69
	Supervisors²		
1.	Name Surname, tel.: 6-666-66666	Metalworker, VK category	71

¹ Number of certificate does not have to be indicated if work is going to be performed by non-energy employee (e.g. construction worker).

² Supervisors are assigned if works in facilities are going to be performed by non-energy employees. If supervised works are performed in power engineering premises, territories supervisor's electrical safety qualification category (VK at least) must be indicated.

(sample list when works will be performed in power facilities)*(to be printed out on the letterhead of legal entity)*Public Company ORLEN Lietuva
Head of Power Plant
Remigijus Kalkauskas

Fax: +370-443-93555

REGARDING ASSIGNMENT OF RESPONSIBLE PERSONS

Execution of works in power facilities of Power Plant is hereby assigned to:

No.	Name, surname	Position	Electrical safety category	Entitled to work in power facilities	Energy employee qualification certificate No
	Work Managers				
1.	Name Surname, Tel.: 7-777-77777	Foreman	AK	No restrictions	786
2.	Name Surname, Tel.: 7-777-77777	Engineer	AK	No restrictions	31
	Work Executors				
1.	Name Surname, Tel.: 7-777-77777	Electrical fitter	AK	No restrictions	780
2.	Name Surname, Tel.: 7-777-77777	Electrical fitter	VK	up to 1000 V	508
	Members of the crew				
1.	Name Surname	Electrical fitter	VK	up to 1000 V	670
2.	Name Surname	Electrical fitter	VK	up to 1000 V	598
3.	Name Surname	Electrical Fitter	VK	up to 1000 V	978
4.	Name Surname	Wireman	VK	up to 1000 V	569
	Supervisors (if applicable)				
1.	Name Surname, Tel.: 7-777-77777	Electrical Fitter	VK	up to 1000 V	978
	Person authorized to sign Statement on Mutual Responsibility Limits (if applicable)				
1.	Name Surname,	Engineer	AK	No restrictions	32

**AKCINĖS BENDROVĖS „ORLEN LIETUVA“
ŠILUMINĖS ELEKTRINĖS
VIRŠININKAS**

Inžinerinių paslaugų pirkimų vadovui
Astai Valienei

Įrengimų priežiūros ir remonto
direktoriaus pavaduotojui
Vaidui Saldukui

TARNYBINIS PRANEŠIMAS

**DĖL REIKALAVIMŲ RANGOVINĖMS ORGANIZACIJOMS ATLIEKANT DARBUS
ŠILUMINĖJE ELEKTRINĖJE**

2013-11-29 Nr. T18(1.52-4)-*1865*
Juodeikių k., Mažeikių r. sav.

1. Reikalavimai dėl atestatų pateikimo

Šiluminėje elektrinėje prieš atliekant darbus šilumos ir elektros įrenginiuose, kuriems atlikti reikalingas Valstybinės energetikos inspekcijos atestatas, suteikiantis teisę atlikti šiuos darbus, juridiniai asmenys privalo pateikti galiojančio dokumento (atestato) kopiją, suteikiančio teisę šiuos darbus atlikti.

2. Darbų saugos reikalavimai

Darbai elektrinės *šilumos (mechanikos)* įrenginiuose atliekami pagal NURODYMUS ir PAVEDIMUS pagal dokumento „Saugos taisyklės eksploatuojant šilumos įrenginius“ reikalavimus, patvirtinto ūkio ministro įsakymu Nr. 316, 1999-09-21.

Darbai elektrinės *elektros* įrenginiuose atliekami pagal NURODYMUS ir PAVEDIMUS pagal dokumento „Saugos eksploatuojant elektros įrenginius taisyklės“ reikalavimus, patvirtinto energetikos ministro įsakymu Nr. 1-100, 2010-03-30.

Šiluminėje elektrinėje prieš atliekant darbus šilumos ir elektros įrenginiuose, juridiniai asmenys šiluminės elektrinės viršininkui privalo pateikti sąrašą darbuotojų, tame tarpe ir subrangovų, nurodant jų kvalifikaciją pagal prieduose (1 priedas, 2 priedas) pateiktas rašto formas. Visa rašto formose reikalaujama informacija turi būti perkelta į firminį įmonės blanką, raštas pasirašytas rangovinės įmonės vadovo ar kitų įmonės vadovaujančių darbuotojų, turinčių tinkamus įgaliojimus ir užregistruotas. Raštas turi būti pristatytas ar išsiųstas šiluminės elektrinės administratorei faksu Nr. 8-443-93555 arba skenuotas elektroniniu paštu dalia.rackauskyte@orlenlietuva.lt.

Pateikti darbuotojų sąrašai galioja ne ilgiau kaip 12 mėn.

PRIDEDAMA: 2 lapai.

Šiluminės elektrinės viršininkas



Remigijus Kalkauskas

(Rašto forma - pavyzdys kai darbai bus atliekami šilumos (mechanikos) įrenginiuose)

(Visa žemiau esanti reikalaujama informacija turi būti perkelta į įmonės firminį blanką)

AB „ORLEN Lietuva “
Šiluminės elektrinės viršininkui
Remigijui Kalkauskui

Faksas: +370-443-93555

DĖL ATSAKINGŲ ASMENŲ PASKYRIMO

Atlikti darbus šiluminės elektrinės šilumos (mechanikos) įrenginiuose skiriami šie asmenys:

Nr.	Vardas, pavardė	Pareigos	Energetikos darbuotojo pažymėjimo Nr. ¹
	Darbų vadovai		
1.	Vardenis Pavardenis, tel 6-666-66666	Meistras	286
2.	Vardenis Pavardenis, tel 6-666-66666	Inžinierius	21
	Darbų vykdytojai		
1.	Vardenis Pavardenis, tel 6-666-66666	Šaltkalvis	78
2.	Vardenis Pavardenis, tel 6-666-66666	Šaltkalvis	508
	Brigados nariai		
1.	Vardenis Pavardenis	Šaltkalvis	670
2.	Vardenis Pavardenis	Šaltkalvis	58
3.	Vardenis Pavardenis	Montuotojas	178
4.	Vardenis Pavardenis	Suvirintojas	69
	Prižiūrintieji²		
1.	Vardenis Pavardenis, tel 6-666-66666	Šaltkalvis, VK kat	71

¹ Kai darbus atlieka ne energetikos darbuotojai (pvz. statybininkai) pažymėjimo numeris nenurodomas.

² Prižiūrintieji skiriami kai darbus įrenginiuose atlieka ne energetikos darbuotojai. Jei darbai prižiūrimi elektrotechnikos patalpose, teritorijose nurodyti prižiūrėtojo elektrosaugos kategoriją (ne žemesnę kaip VK).

(Rašto forma-pavyzdys kai darbai bus atliekami elektros įrenginiuose)*(Visa žemiau esanti reikalaujama informacija turi būti perkelta į įmonės firminį blanką)*

AB "ORLEN Lietuva"
Šiluminės elektrinės viršininkui
Remigijui Kalkauskui

Faksas: +370-443-93555

DĖL ATSAKINGŲ ASMENŲ PASKYRIMO

Atlikti darbus šiluminės elektrinės elektros įrenginiuose skiriami šie asmenys:

Nr.	Vardas, pavardė	Pareigos	Elektro-saugos kategorija	Turi teisę dirbti elektros įrenginiuose	Energetikos darbuotojo kvalifikacijos atestato Nr.
	Darbų vadovai				
1.	Vardenis Pavardenis tel. 7-777-77777	Meistras	AK	Be apribojimų	786
2.	Vardenis Pavardenis, tel. 7-777-77777	Inžinierius	AK	Be apribojimų	31
	Darbų vykdytojai				
1.	Vardenis Pavardenis tel. 7-777-77777	Elektosaltkalvis	AK	Be apribojimų	780
2.	Vardenis Pavardenis, tel. 7-777-77777	Elektosaltkalvis	VK	Iki 1000 V	508
	Brigados nariai				
1.	Vardenis Pavardenis	Elektosaltkalvis	VK	Iki 1000 V	670
2.	Vardenis Pavardenis	Elektosaltkalvis	VK	Iki 1000 V	598
3.	Vardenis Pavardenis	Elektosaltkalvis	VK	Iki 1000 V	978
4.	Vardenis Pavardenis	Elektomontuotojas	VK	Iki 1000 V	569
	Prižiūrintieji (jei reikalinga)				
1.	Vardenis Pavardenis, tel. 7-777-77777	Elektosaltkalvis	VK	Iki 1000 V	978
	Asmuo įgaliotas pasirašyti atsakomybės ribų aktą (jei reikalinga)				
1.	Vardenis Pavardenis,	Inžinierius	AK	Be apribojimų	32