

AUTOMATIZUOTOS MATAVIMŲ SISTEMOS 2024 M. SPALIO MĖN. DUOMENŲ PALYGINIMAS SU RIBINĖMIS VERTĖMIS
(prie spalio mėn. protokolų)

Taršos šaltinio pavadinimas	Taršos šaltinio Nr.	CO (vidutinė mėnesio koncentracija)	Kietosios dalelės (vidutinė mėnesio koncentracija)	Apibendrinta SO₂ koncentracija	Apibendrinta NO_x koncentracija
Gamybos padalinys Nr.1, naftos pirminio perdirbimo komplekso LK Nr.1 įrenginio kaminas	001	Neviršijo vidutinės mėnesio ribinės vertės	Neviršijo vidutinės mėnesio ribinės vertės	*	**
Gamybos padalinys Nr.1, naftos pirminio perdirbimo komplekso LK Nr.2 įrenginio kaminas	006	Neviršijo vidutinės mėnesio ribinės vertės	Neviršijo vidutinės mėnesio ribinės vertės	*	**
Gamybos padalinys Nr.2, mazuto giluminio perdirbimo kompleksas KT-1/1, sekcijų S-001/100 krosnių blokas	100_1	Neviršijo vidutinės mėnesio ribinės vertės	Neviršijo vidutinės mėnesio ribinės vertės	*	**
Gamybos padalinys Nr.2, mazuto giluminio perdirbimo kompleksas KT-1/1, sekcija S-200 (katalizinio krekingo įrenginys)	100_2	Neviršijo vidutinės mėnesio ribinės vertės	Neviršijo vidutinės mėnesio ribinės vertės	*	**
Gamybos padalinys Nr.2, vandenilio gamybos įrenginio kaminas.	104	Neviršijo vidutinės mėnesio ribinės vertės	Neviršijo vidutinės mėnesio ribinės vertės	*	**
Šiluminės elektrinės kaminas	301	Neviršijo vidutinės mėnesio ribinės vertės	Neviršijo vidutinės mėnesio ribinės vertės	*	**
Elementinės sieros gamybos įrenginio Nr.1 kaminas	015	-	-	*	-
Elementinės sieros gamybos įrenginio Nr.2 kaminas	108	-	-	*	-
Apibendrinta SO ₂ koncentracija pagal 58 GPGB	-	-	-	Neviršijo vidutinės mėnesio ribinės vertės	-
Apibendrinta NO _x koncentracija pagal 57 GPGB	-	-	-	-	Neviršijo vidutinės mėnesio ribinės vertės

* - Katalizinio krekingo proceso įrenginio ir kurą deginančių įrenginių pagal 58 GPGB numatomas normatyvas (vienkartinis dydis, išreikštas mg/Nm³ (mėnesio vidutinė vertė)), nurodytas kaip apibendrinta SO₂ vertė visiems dešimčiai susijusių taršos šaltinių (a.t.š. Nr.001, 006, 100_1, 100_2, 104, 011, 157, 301, 015, 108).

** - Katalizinio krekingo proceso įrenginio ir kurą deginančių įrenginių pagal 57 GPGB numatomas normatyvas (vienkartinis dydis, išreikštas mg/Nm³ (mėnesio vidutinė vertė)), nurodytas kaip apibendrinta NO_x vertė visiems aštuoniems susijusiems taršos šaltiniams (a.t.š. Nr.001, 006, 100_1, 100_2, 104, 011, 157, 301).

LK-1, kaminas (poz. LK-1 ch). T.š. 001

Monthly-Protocol from 01-10-2024 to 31.10.2024

Daily averages

	CO	NO ₂ *	SO ₂ **	Dust	O ₂	Flow	Flow O ₂
Limit value mg/Nm ³	100	256.39 *	1482.34**	50			
Time	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Vol%	Nm ³ /h	Nm ³ /h
01.10.24	0,0	208,1	16,8	0,0	14,5	132743	48013
02.10.24	0,0	177,4	13,7	0,0	15,2	123100	39690
03.10.24	0,0	182,2	9,8	0,0	15,2	122801	39737
04.10.24	0,0	186,2	20,4	0,0	15,2	123826	40214
05.10.24	0,0	191,3	23,3	0,0	15,1	123763	40391
06.10.24	11,7	170,1	7,5	0,0	15,4	117004	36263
07.10.24	0,1	156,1	0,0	0,0	15,6	101629	30469
08.10.24	-	-	-	-	-	-	-
09.10.24	-	-	-	-	-	-	-
10.10.24	-	-	-	-	-	-	-
11.10.24	-	-	-	-	-	-	-
12.10.24	-	-	-	-	-	-	-
13.10.24	-	-	-	-	-	-	-
14.10.24	-	-	-	-	-	-	-
15.10.24	-	-	-	-	-	-	-
16.10.24	-	-	-	-	-	-	-
17.10.24	-	-	-	-	-	-	-
18.10.24	-	-	-	-	-	-	-
19.10.24	-	-	-	-	-	-	-
20.10.24	-	-	-	-	-	-	-
21.10.24	-	-	-	-	-	-	-
22.10.24	-	-	-	-	-	-	-
23.10.24	1,6	168,2	0,0	0,0	15,4	67210	21369
24.10.24	0,9	164,3	32,5	0,0	15,6	69184	21117
25.10.24	0,6	197,0	0,0	0,0	15,4	63245	19890
26.10.24	3,0	218,0	12,4	0,0	15,4	58344	18439
27.10.24	2,5	204,2	0,0	0,0	15,3	55389	17875
28.10.24	0,4	211,8	0,0	0,0	15,4	58827	18580
29.10.24	1,5	195,5	0,0	0,0	15,2	56329	18456
30.10.24	5,8	180,8	0,0	0,4	15,3	57700	18672
31.10.24	10,0	168,1	252,2	8,8	15,5	60892	18982
min	0,0	0,0	0,0	0,0	0,0	0	0
max	11,7	218,0	252,2	8,8	15,6	132743	48013
AVG	2,5	187,9	25,8	0,6	15,3	86838	28052
-----	kg/mon	kg/mon	kg/mon	kg/mon	-----	-----	-----
EMI	27,0	1902,5	231,7	4,3	-----	-----	-----

(N)odata (M)aintenance (E)rror (F)ault (-)Out of Operation

(X) No Daily-average (L) Month-Limit-value-Overflow (Emi)ssion per month

* single measured value of nitrogen dioxide is given in general for all concerned units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157) according BAT 57) calculated in proportion in every measurement point determined flow rate.

** single measured value of sulphur dioxide is given in general for all concerned units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157, 015, 108) according BAT 58) calculated in proportion in every measurement point determined flow rate.

Monthly-Protocol from 01-10-2024 to 31.10.2024

Daily averages

	CO	NO ₂ *	SO ₂ **	Dust	O ₂	Flow	Flow O ₂
Limit value mg/Nm ³	100	256.39 *	1482.34**	26			
Time	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Vol%	Nm ³ /h	Nm ³ /h
01.10.24	5,5	131,3	9,2	3,1	3,8	183524	181360
02.10.24	5,3	129,8	14,1	3,1	3,9	178148	175152
03.10.24	4,0	134,6	9,1	3,0	3,9	170284	167073
04.10.24	2,0	138,5	8,6	3,2	4,1	177962	173055
05.10.24	0,7	142,6	10,3	2,9	4,1	174320	168909
06.10.24	0,7	153,9	9,8	3,2	4,8	198712	183536
07.10.24	3,8	154,6	17,0	4,4	6,7	200571	162000
08.10.24	2,4	140,9	5,3	3,7	6,7	158744	130807
09.10.24	0,7	136,5	2,0	3,7	6,8	154614	126877
10.10.24	0,2	134,7	3,5	3,3	6,9	133439	109061
11.10.24	0,0	144,4	3,9	4,3	7,1	126324	102107
12.10.24	0,6	139,6	1,0	3,6	6,9	125176	102870
13.10.24	2,3	137,0	0,0	3,7	6,9	129714	106687
14.10.24	2,3	139,3	0,4	4,1	7,0	137948	111978
15.10.24	1,7	146,2	0,3	3,6	7,1	141585	114097
16.10.24	2,5	148,4	0,0	3,6	7,1	166326	133452
17.10.24	4,1	148,6	0,0	3,3	7,0	180321	145469
18.10.24	3,2	152,4	4,7	4,0	7,2	175805	138722
19.10.24	3,2	150,5	5,4	3,8	7,1	176110	140250
20.10.24	3,5	152,4	1,0	4,2	7,1	173813	138206
21.10.24	2,7	148,9	2,5	3,8	7,1	174250	138273
22.10.24	0,0	147,5	5,4	4,0	7,1	174863	138441
23.10.24	0,0	152,8	8,2	3,7	7,3	165426	130265
24.10.24	0,0	155,0	83,2	4,5	7,4	150185	117459
25.10.24	0,9	151,6	10,5	3,6	7,0	132116	107279
26.10.24	1,1	146,8	15,9	3,9	6,2	135027	115849
27.10.24	0,9	147,4	24,8	3,9	6,4	132427	112472
28.10.24	0,1	151,4	32,2	3,8	6,5	140774	117860
29.10.24	0,2	151,2	77,8	4,0	6,7	143223	118717
30.10.24	0,1	152,9	214,8	4,3	6,9	141831	114896
31.10.24	1,1	151,5	140,3	3,4	6,8	138943	113772
min	0,0	129,8	0,0	2,9	3,8	125176	102107
max	5,5	155,0	214,8	4,5	7,4	200571	183536
AVG	1,8	145,6	23,3	3,7	6,4	157789	133422
-----	kg/mon	kg/mon	kg/mon	kg/mon	-----	-----	-----
EMI	197,3	14455,9	2093,9	363,9	-----	-----	-----

(N)odata (M)aintenance (E)rror (F)ault (-)Out of Operation

(X) No Daily-average (L) Month-Limit-value-Overflow (Emi)ssion per month

* single measured value of nitrogen dioxide is given in general for all concerned

units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157) according BAT 57)

calculated in proportion in every measurement point determinated flow rate.

** single measured value of sulphur dioxide is given in general for all concerned

units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157, 015, 108) according BAT 58)

calculated in proportion in every measurement point determinated flow rate.

KT-1/1, S-001/100 (poz. AT5-454). T.š. 100_1

Monthly-Protocol from 01-10-2024 to 31.10.2024

Daily averages

	CO	NO ₂ *	SO ₂ **	Dust	O ₂	Flow	Flow O ₂
Limit value mg/Nm ³	100	256.39 *	1482.34**	26			
Time	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Vol%	Nm ³ /h	Nm ³ /h
01.10.24	44,9	113,3	0,0	5,8	7,4	156733	122038
02.10.24	63,1	115,8	0,0	5,4	7,4	152771	119063
03.10.24	38,5	112,5	0,0	4,6	6,7	155218	127031
04.10.24	34,7	109,8	0,0	4,6	6,6	154187	126358
05.10.24	36,1	115,1	0,0	4,7	6,7	154695	125972
06.10.24	42,7	129,1	0,0	5,2	7,8	150789	113899
07.10.24	1057,7	198,0	299,0	4,8	16,3	77383	25023
08.10.24	0,0	0,0	0,0	0,0	0,0	0	0
09.10.24	-	-	-	-	-	-	-
10.10.24	-	-	-	-	-	-	-
11.10.24	-	-	-	-	-	-	-
12.10.24	-	-	-	-	-	-	-
13.10.24	-	-	-	-	-	-	-
14.10.24	-	-	-	-	-	-	-
15.10.24	-	-	-	-	-	-	-
16.10.24	-	-	-	-	-	-	-
17.10.24	21,8	120,8	56,0	0,8	18,5	11070	2129
18.10.24	24,1	156,8	30,9	0,6	18,0	10603	2490
19.10.24	46,3	123,1	53,9	0,6	18,4	10242	2097
20.10.24	48,9	133,8	43,4	0,5	18,3	10464	2221
21.10.24	30,2	146,4	47,7	0,7	17,8	24939	5863
22.10.24	33,9	63,0	135,5	0,5	18,5	9496	1924
23.10.24	57,8	157,3	31,2	0,6	14,2	86776	41289
24.10.24	6,6	140,7	697,0	0,7	10,7	93111	55499
25.10.24	20,6	156,4	410,9	0,7	9,6	80834	54281
26.10.24	5,5	153,0	722,0	0,5	9,1	87262	60548
27.10.24	0,0	151,0	1482,8	0,4	9,2	86665	59426
28.10.24	0,0	154,6	1546,1	0,3	9,1	97090	67227
29.10.24	0,0	149,7	2391,4	0,3	9,0	93700	65285
30.10.24	0,0	139,3	3398,7	0,4	8,7	88228	62996
31.10.24	0,0	136,0	1909,3	0,5	8,8	99464	69439
min	0,0	0,0	0,0	0,0	0,0	0	0
max	1057,7	198,0	3398,7	5,8	18,5	156733	127031
AVG	73,2	135,3	604,2	2,0	11,7	85989	59640
-----	kg/mon	kg/mon	kg/mon	kg/mon	-----	-----	-----
EMI	1387,8	4148,6	18723,3	98,2	-----	-----	-----

(N)odata (M)aintenance (E)rror (F)ault (-)Out of Operation

(X) No Daily-average (L) Month-Limit-value-Overflow (Emi)ssion per month

* single measured value of nitrogen dioxide is given in general for all concerned

units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157) according BAT 57)

calculated in proportion in every measurement point determined flow rate.

** single measured value of sulphur dioxide is given in general for all concerned

units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157, 015, 108) according BAT 58)

calculated in proportion in every measurement point determined flow rate.

KT-1/1, S-200 (poz. AT5-456). T.š. 100_2

Monthly-Protocol from 01-10-2024 to 31.10.2024

Daily averages

	CO	NO ₂ *	SO ₂ **	Dust	O ₂	Flow	Flow O ₂
Limit value mg/Nm ³	100	256.39 *	1482.34**	50			
Time	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Vol%	Nm ³ /h	Nm ³ /h
01.10.24	34,7	27,7	95,3	8,3	1,8	119941	133029
02.10.24	39,0	29,4	105,4	9,4	1,9	124740	137414
03.10.24	39,0	30,9	143,7	7,1	1,9	134360	147667
04.10.24	28,4	32,4	181,9	5,9	1,7	138491	153919
05.10.24	36,0	32,3	178,5	6,0	1,8	140393	154554
06.10.24	39,4	29,4	119,9	12,2	2,0	118137	130173
07.10.24	311,7	21,8	142,1	77,0	3,6	81398	84003
08.10.24	-	-	-	-	-	-	-
09.10.24	-	-	-	-	-	-	-
10.10.24	-	-	-	-	-	-	-
11.10.24	-	-	-	-	-	-	-
12.10.24	-	-	-	-	-	-	-
13.10.24	-	-	-	-	-	-	-
14.10.24	-	-	-	-	-	-	-
15.10.24	-	-	-	-	-	-	-
16.10.24	-	-	-	-	-	-	-
17.10.24	-	-	-	-	-	-	-
18.10.24	-	-	-	-	-	-	-
19.10.24	-	-	-	-	-	-	-
20.10.24	-	-	-	-	-	-	-
21.10.24	-	-	-	-	-	-	-
22.10.24	-	-	-	-	-	-	-
23.10.24	-	-	-	-	-	-	-
24.10.24	824,9	38,7	268,3	447,6	8,0	88357	68054
25.10.24	153,8	46,3	785,5	130,5	3,3	86805	90280
26.10.24	21,1	54,7	1031,3	8,2	2,2	92305	101397
27.10.24	21,8	60,5	1039,2	11,8	2,6	93565	100639
28.10.24	25,8	48,7	1152,7	6,9	2,4	96837	105048
29.10.24	23,9	59,9	1111,4	2,3	2,5	101934	109829
30.10.24	24,4	54,0	1263,6	2,3	2,2	99765	109122
31.10.24	28,5	42,9	1591,1	5,6	1,9	115117	126414
min	0,0	0,0	0,0	0,0	0,0	0	0
max	824,9	60,5	1591,1	447,6	8,0	140393	154554
AVG	69,7	41,7	652,3	30,8	2,4	111027	120456
	kg/mon	kg/mon	kg/mon	kg/mon			
EMI	2099,9	1602,2	24020,3	852,9			

(N)odata (M)aintenance (E)rror (F)ault (-)Out of Operation

(X) No Daily-average (L) Month-Limit-value-Overflow (Emi)ssion per month

* single measured value of nitrogen dioxide is given in general for all concerned

units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157) according BAT 57)

calculated in proportion in every measurement point determined flow rate.

** single measured value of sulphur dioxide is given in general for all concerned

units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157, 015, 108) according BAT 58)

calculated in proportion in every measurement point determined flow rate.

Monthly-Protocol from 01-10-2024 to 31.10.2024

Daily averages

	CO	NO ₂ *	SO ₂ **	Dust	O ₂	Flow	Flow O ₂
Limit value mg/Nm ³	100	256.39 *	1482.34**	26			
Time	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Vol%	Nm ³ /h	Nm ³ /h
01.10.24	0,0	99,9	0,0	0,0	5,2	86511	77962
02.10.24	0,0	90,4	0,0	0,0	4,3	90789	86351
03.10.24	0,3	89,7	0,1	0,0	4,1	93320	89837
04.10.24	0,0	87,9	0,0	0,0	3,9	96874	94434
05.10.24	0,0	87,3	0,0	0,0	3,8	97036	95024
06.10.24	0,0	97,4	0,0	0,0	4,9	91435	84487
07.10.24	0,0	481,3	0,0	0,0	11,1	82715	47618
08.10.24	0,0	872,0	0,0	0,0	17,9	63099	11991
09.10.24	-	-	-	-	-	-	-
10.10.24	-	-	-	-	-	-	-
11.10.24	-	-	-	-	-	-	-
12.10.24	-	-	-	-	-	-	-
13.10.24	-	-	-	-	-	-	-
14.10.24	-	-	-	-	-	-	-
15.10.24	-	-	-	-	-	-	-
16.10.24	-	-	-	-	-	-	-
17.10.24	-	-	-	-	-	-	-
18.10.24	-	-	-	-	-	-	-
19.10.24	-	-	-	-	-	-	-
20.10.24	-	-	-	-	-	-	-
21.10.24	-	-	-	-	-	-	-
22.10.24	-	-	-	-	-	-	-
23.10.24	-	-	-	-	-	-	-
24.10.24	-	-	-	-	-	-	-
25.10.24	-	-	-	-	-	-	-
26.10.24	-	-	-	-	-	-	-
27.10.24	-	-	-	-	-	-	-
28.10.24	-	-	-	-	-	-	-
29.10.24	-	-	-	-	-	-	-
30.10.24	-	-	-	-	-	-	-
31.10.24	-	-	-	-	-	-	-
min	0,0	0,0	0,0	0,0	0,0	0	0
max	0,3	872,0	0,1	0,0	17,9	97036	95024
AVG	0,0	164,5	0,0	0,0	5,6	90586	80611
-----	kg/mon	kg/mon	kg/mon	kg/mon	-----	-----	-----
EMI	0,7	1563,6	0,1	0,0	-----	-----	-----

(N)odata (M)aintenance (E)rror (F)ault (-)Out of Operation

(X) No Daily-average (L) Month-Limit-value-Overflow (Emi)ssion per month

* single measured value of nitrogen dioxide is given in general for all concerned

units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157) according BAT 57)

calculated in proportion in every measurement point determined flow rate.

** single measured value of sulphur dioxide is given in general for all concerned

units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157, 015, 108) according BAT 58)

calculated in proportion in every measurement point determined flow rate.

Monthly-Protocol from 01-10-2024 to 31.10.2024

Daily averages

	CO	NO ₂ *	SO ₂ **	Dust	O ₂	Flow	Flow O ₂
Limit value mg/Nm ³	100	256.39 *	1482.34**	50			
Time	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Vol%	Nm ³ /h	Nm ³ /h
01.10.24	0,3	319,8	1677,4	16,2	6,3	179223	147747
02.10.24	0,0	392,7	1603,5	19,2	5,8	228473	194570
03.10.24	0,0	376,6	1521,9	15,9	5,8	220620	187849
04.10.24	0,6	314,4	1349,8	10,4	6,4	164447	134809
05.10.24	0,0	312,9	1292,8	7,5	6,7	162407	130573
06.10.24	0,0	277,4	1277,6	8,9	6,7	163724	131297
07.10.24	3,9	394,1	1445,1	18,8	6,2	256834	210201
08.10.24	0,0	342,4	1336,3	11,8	5,9	222984	187798
09.10.24	0,0	286,5	1062,7	10,8	6,0	185933	155758
10.10.24	14,6	304,5	1059,2	18,4	6,3	213895	170571
11.10.24	1,8	295,6	1070,6	14,7	6,0	180788	151146
12.10.24	1,2	327,8	944,2	12,0	6,1	179248	150275
13.10.24	1,4	283,0	888,5	10,9	6,1	162330	135712
14.10.24	2,4	334,0	874,6	9,7	5,6	190856	164964
15.10.24	1,5	328,4	849,2	9,8	5,6	184154	159414
16.10.24	1,4	337,6	829,0	9,7	5,7	182427	157413
17.10.24	1,5	302,1	751,3	8,9	6,0	160636	135155
18.10.24	1,4	315,8	748,3	8,3	5,9	167835	141914
19.10.24	1,4	310,6	726,6	8,0	6,1	160906	134781
20.10.24	1,4	306,5	730,2	7,7	6,1	159432	133467
21.10.24	1,7	322,7	734,3	7,5	5,9	176031	149728
22.10.24	3,0	347,3	801,4	8,1	5,8	251592	207330
23.10.24	1,8	313,7	904,4	13,0	5,5	177092	154373
24.10.24	1,5	383,1	880,2	10,5	5,1	207160	184810
25.10.24	1,7	396,5	735,7	5,7	5,1	218143	194491
26.10.24	1,3	396,2	1346,5	14,9	5,2	220980	196077
27.10.24	1,7	270,2	1140,1	12,7	5,6	189010	163105
28.10.24	0,5	387,2	1478,9	13,6	5,6	217719	188574
29.10.24	1,0	397,4	1911,4	14,5	5,1	222629	199457
30.10.24	1,2	297,6	1398,8	12,3	5,9	190961	161216
31.10.24	2,1	311,3	1065,7	10,6	6,5	195200	159043
min	0,0	270,2	726,6	5,7	5,1	159432	130573
max	14,6	397,4	1911,4	19,2	6,7	256834	210201
AVG	1,7	331,7	1110,9	11,6	5,9	193338	163664
	kg/mon	kg/mon	kg/mon	kg/mon			
EMI	226,0	42038,4	139343,2	1500,7			

(N)odata (M)aintenance (E)rror (F)ault (-)Out of Operation

(X) No Daily-average (L) Month-Limit-value-Overflow (Emi)ssion per month

* single measured value of nitrogen dioxide is given in general for all concerned units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157) according BAT 57) calculated in proportion in every measurement point determined flow rate.

** single measured value of sulphur dioxide is given in general for all concerned units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157, 015, 108) according BAT 58) calculated in proportion in every measurement point determined flow rate.

SGI-1, kaminas (poz. SGI-1ch). T.š. 015

Monthly-Protocol from 01-10-2024 to 31.10.2024

Daily averages

	SO ₂	O ₂	Flow	Flow O ₂
Limit value mg/Nm ³	1482.34**			
Time	mg/Nm ³	Vol%	Nm ³ /h	Nm ³ /h
01.10.24	19060,1	4,4	11812	11477
02.10.24	18657,8	3,4	14191	14485
03.10.24	18805,3	3,5	15147	15272
04.10.24	19072,9	3,6	15164	15198
05.10.24	18463,9	3,5	15436	15590
06.10.24	18008,5	4,0	13818	13640
07.10.24	17367,9	4,6	10334	10003
08.10.24	-	-	-	-
09.10.24	-	-	-	-
10.10.24	-	-	-	-
11.10.24	-	-	-	-
12.10.24	-	-	-	-
13.10.24	-	-	-	-
14.10.24	-	-	-	-
15.10.24	-	-	-	-
16.10.24	-	-	-	-
17.10.24	-	-	-	-
18.10.24	-	-	-	-
19.10.24	-	-	-	-
20.10.24	-	-	-	-
21.10.24	-	-	-	-
22.10.24	-	-	-	-
23.10.24	0,0	0,0	0	0
24.10.24	-	-	-	-
25.10.24	-	-	-	-
26.10.24	-	-	-	-
27.10.24	21131,9	2,0	23972	9276
28.10.24	21686,6	2,5	24530	9422
29.10.24	16899,7	2,0	24881	10429
30.10.24	17348,5	2,4	24320	11690
31.10.24	16332,5	2,3	23778	12567
min	0,0	0,0	0	0
max	21686,6	4,6	24881	15590
AVG	18553,5	3,1	18470	12744
-----	kg/mon	-----	-----	-----
EMI	60265,8	-----	-----	-----

(N)odata (M)aintenance (E)rror (F)ault (-)Out of Operation

(X) No Daily-average (L) Month-Limit-value-Overflow (Emi)ssion per month

** single measured value of sulphur dioxide is given in general for all concerned units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157, 015, 108) according BAT 58) calculated in proportion in every measurement point determined flow rate.

SGI-2, kaminas (poz. SGI-2ch). T.š. 108

Monthly-Protocol from 01-10-2024 to 31.10.2024

Daily averages

	SO ₂	O ₂	Flow	Flow O ₂
Limit value mg/Nm ³	1482.34**			
Time	mg/Nm ³	Vol%	Nm ³ /h	Nm ³ /h
01.10.24	21033,5	5,7	19756	17125
02.10.24	21142,4	4,3	21398	20205
03.10.24	21754,8	4,0	22448	21543
04.10.24	22423,6	3,9	22988	22177
05.10.24	24016,6	4,1	23210	22155
06.10.24	22520,5	4,9	21486	19672
07.10.24	20150,4	5,8	14067	9010
08.10.24	0,0	5,2	11455	5048
09.10.24	0,0	5,0	11262	5258
10.10.24	0,0	5,1	11140	5353
11.10.24	436,1	5,9	11506	5045
12.10.24	2486,6	7,1	11859	4302
13.10.24	3547,1	6,8	11231	4122
14.10.24	37961,6	7,1	10835	3760
15.10.24	80018,8	7,0	10916	3861
16.10.24	64769,7	5,5	11152	4773
17.10.24	74449,9	6,5	11523	4397
18.10.24	22461,3	4,6	11927	6007
19.10.24	40056,8	6,8	12757	5302
20.10.24	22447,7	6,7	12763	5393
21.10.24	17559,2	7,0	12834	5392
22.10.24	53193,0	6,9	12799	5496
23.10.24	3529,5	5,7	13675	6303
24.10.24	46589,7	5,6	13959	6622
25.10.24	34794,8	5,2	14058	6947
26.10.24	29307,3	3,3	14921	9121
27.10.24	27320,0	3,1	15390	9869
28.10.24	-	-	-	-
29.10.24	-	-	-	-
30.10.24	28027,7	3,2	12846	7767
31.10.24	-	-	-	-
min	0,0	0,0	0	0
max	80018,8	7,1	23210	22177
AVG	26429,3	5,6	14549	9029
-----	kg/mon	-----	-----	-----
EMI	138397,6	-----	-----	-----

(N)odata (M)aintenance (E)rror (F)ault (-)Out of Operation

(X) No Daily-average (L) Month-Limit-value-Overflow (Emi)ssion per month

** single measured value of sulphur dioxide is given in general for all concerned units ((No. 001, 006, 100_1, 301, 100_2, 104, 011, 157, 015, 108) according BAT 58) calculated in proportion in every measurement point determined flow rate.

Apibendrinta SO₂ vertė pagal 58 GPGB, (SO₂ bubble concerned units)

Monthly-Protocol from 01-10-2024 to 31.10.2024
daily averages

	SO ₂ BAT58	Flow O ₂ BAT58
Limit value, mg/Nm ³	1482.34 **	
Time	mg/Nm ³	Nm ³ /h
01.10.24	1113,3	760064
02.10.24	1275,3	808240
03.10.24	1311,8	817321
04.10.24	1286,4	781477
05.10.24	1324,1	774479
06.10.24	1201,3	734279
07.10.24	956,3	554710
08.10.24	711,6	359897
09.10.24	538,3	318715
10.10.24	603,4	311603
11.10.24	596,1	284093
12.10.24	546,9	284474
13.10.24	514,2	271904
14.10.24	909,7	307269
15.10.24	1465,1	302947
16.10.24	1385,2	323225
17.10.24	1335,5	325325
18.10.24	621,8	356468
19.10.24	927,1	334650
20.10.24	650,6	331490
21.10.24	592,8	349877
22.10.24	1110,5	404857
23.10.24	408,9	403672
24.10.24	1083,6	466709
25.10.24	976,4	495440
26.10.24	1315,6	523155
27.10.24	1275,2	485228
28.10.24	1361,8	528429
29.10.24	1565,2	543874
30.10.24	1604,6	501002
31.10.24	1394,7	522686
min	408,9	271904
max	1604,6	817321
AVG	1031,4	469942
	kg/mon	
EMI	386427,2	

(N)o data (M)aintenance (E)rror (F)ault (S)ubstitute Value (-)Out of operation

(X) No Daily-average (L) Month-Limit-value-Overflow

** single measured value of sulphur dioxide is given in general for all

concerned units ((No. 001,006,301,100_1,100_2,104,011,157,015,108) according BAT 58)

and is calculated in proportion in every measurement point determined flow rate.

Apibendrinta NO_x vertė pagal 57 GPGB, (NO_x bubble concerned units)

Monthly-Protocol from 01-10-2024 to 31.10.2024
daily averages

	NO ₂ BAT57	Flow O ₂ BAT57
Limit value, mg/Nm ³	256.39 *	
Time	mg/Nm ³	Nm ³ /h
01.10.24	149,2	731461
02.10.24	174,3	773551
03.10.24	167,6	780505
04.10.24	139,2	744101
05.10.24	141,3	736733
06.10.24	144,3	700967
07.10.24	256,8	543694
08.10.24	252,2	354849
09.10.24	204,5	313456
10.10.24	225,1	306250
11.10.24	222,5	279048
12.10.24	238,0	280172
13.10.24	206,7	267782
14.10.24	240,3	303510
15.10.24	238,4	299085
16.10.24	237,4	318452
17.10.24	201,6	320928
18.10.24	195,9	350461
19.10.24	198,0	329348
20.10.24	199,2	326097
21.10.24	210,4	344485
22.10.24	234,7	399361
23.10.24	199,9	397369
24.10.24	227,0	460087
25.10.24	230,6	488493
26.10.24	228,4	514034
27.10.24	171,9	475242
28.10.24	221,9	519006
29.10.24	227,1	533445
30.10.24	174,7	488600
31.10.24	169,1	510119
min	139,2	267782
max	256,8	780505
AVG	204,1	457788
-----	kg/mon	-----
EMI	67085,2	-----

(N)o data (M)aintenance (E)rror (F)ault (S)ubstitute Value (-)Out of operation

(X) No Daily-average (L) Month-Limit-value-Overflow

* single measured value of nitrogen oxides is given in general for all

concerned units ((No. 001,006,301,100_1,100_2,104,011,157) according BAT 57)

and is calculated in proportion in every measurement point determined flow rate.